



NOTES:

1. GATE AND FENCE SHALL BE DESIGNED TO CITY OF OREGON CITY CONSTRUCTION STANDARDS.
2. FENCE MATERIAL SHALL BE NO. 11 GAUGE GALVANIZED STEEL FABRIC WITH BONDED VINYL COATING (BLACK).
3. POSTS SHALL BE GALVANIZED STEEL, WITH TOP CAPS.
4. CROSS BARS SHALL CONNECT ADJACENT FENCE POSTS WITH DIAGONAL BRACES AT CORNERS AND ENDS.
5. SEE PLAN FOR LOCATION OF GATE AND FENCE.
6. ALL GATE AND FENCE MATERIALS (INCLUDING CHAIN LINK, FABRIC, POSTS, RAILS, ETC.) SHALL BE COVERED WITH BLACK-COLORED VINYL COATING. THE COLOR SHOULD BE THE SAME FOR ALL GATE AND FENCE MATERIALS.
7. CONCRETE FOOTING SHALL BE AS FOLLOWS:
 - * FENCE – 12" MINIMUM DIAMETER X 30" DEEP, 3,000 PSI CONCRETE.
 - * GATE – 12" MINIMUM DIAMETER X 42" DEEP, 3,000 PSI CONCRETE.



Public Works Standard Drawings

CHAIN LINK FENCE AND GATE

SCALE	NTS	
DATE	JAN '23	REV.
ENGR.	DW	DRAWN
DRAWING NO.	633	